

Funded by



November 16, 2021



Deerfield Town Hall Church Street

Audit Prepared by





Table of Contents

Introduction	3
Executive Summary	3-4
Inputs, Assumptions, & Loads	5
Floor Plan Graphics	6-7
Historic Energy Data	8-9
IR Images and ESM Descriptions	10-12

Elite Heating Load Calc Reports

Existing Conditions	13-21
Improved Conditions	22-26



Introduction

This Energy Audit has been funded by Eversource. Funds may, or may not, also be available to help reduce cost for eligible Energy Saving Measures (ESM) including weatherization efforts, lighting and equipment upgrades.

The purpose of an energy audit is to identify ESM in a building. Computer simulated and other energy models were developed for this project using multiple strategies and software. The models estimate predicted future energy consumption based on the local climate conditions, physical dimensions and characteristics of a building, mechanical systems, presumed lighting, equipment, and occupancy patterns, in addition to a number of other variables.

With the building modeled in existing conditions, energy savings can be estimated for improvements to the thermal envelope. The cost of those measures can then be analyzed in terms of predicted energy saved. The primary objective is to evaluate the level of investment warranted by energy and dollars saved from those specific measures. In many cases, as in this one, improving the thermal envelope is expected to yield 'non energy saving' benefits, such as improving occupant comfort, building durability, and reducing the size of any future HVAC equipment.

This audit has been prepared with the best of intentions to assist the Town of Deerfield make informed decisions regarding energy improvements while also helping Eversource determine if the ESM warrant financial incentives. We do not make any warranty, expressed or implied, or assume any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product or process disclosed.

Executive Summary

The Deerfield Town Hall was constructed in 1856 and noted as one of New Hampshire's best public examples of Greek Revival Architecture. It is a two story post and beam structure with a granite crawlspace foundation with dirt floor. Each floor is heated by its own oil fired forced hot air furnace.

The first floor is used infrequently for town meetings. The second floor has a large room and stage for community events and two smaller rooms which house articles belonging to the historical society. The building has had little to no use over the past 12 years, though has been heated up until this year.

The Town is seeking to restore the building and bring it up to meet codes in order to bring it back into full use.

This study offers five ESM which will result in significant reductions in energy consumption while also improving comfort and contributing to the overall durability and well being of the building.

A summary of energy and dollar savings can be found on the next page with more details described in pages 10-12.



Energy Audit

The chart below summarizes four ESM in terms of estimated installed costs and predicted energy savings in gallons of oil and MMBTU, as well as the annual reduction of CO2 emissions from completing those measures. The lower chart summarizes the savings in terms of dollars for supply and delivery, based on the current price of \$3.25 per gallon. The ESM are briefly described in the notes below with more details in following pages.

ESM #	Envelope Con- dition / ESM	Cost of Measure	Oil Gallons Saved	Site Energy Reduction MMBTU	Source Energy Reduction	Tons CO2 Reductions Annually
1	AS & Attic	\$7,36 0	170	23.6	26.0	1.9
2	Foundation	\$7,800	257	35.5	39.1	2.9
3	Window Ret	\$15,000	329	45.6 50.		3.7
4	Interior Panels	\$5,214	1022	141.6	155.7	11.4
	ESM 1-4	\$35,374	1778	246.3	270.9	19.9
5	Walls	\$24,700	381	52.8	58.1	4.3
ESM 1-5	TOTALS	\$60,074	2159	299.1	329.0	24.1

ESM #	Envelope Con- dition / ESM	Cost of Measure	Annual Savings	Simple Payback Years	Life of Measure	Invest- ment Gain	ROI	Annual ROI
1	AS & Attic	\$7,36 0	\$554	13.3	25	\$6,490	88.2%	2.6%
2	Foundation	\$7,800	\$834	9.4	25	\$13,050	167.3%	4.0%
3	Window Ret	\$15,000	\$1,069	14.0	25	\$11,725	78.2%	2.3%
4	Interior Panels	\$5,214	\$3,322	1.6	25	\$77,836	1492.8%	11.7%
	ESM 1-4	\$35,374	\$5,779	6.1	25	\$109,101	308.4%	5.8%
5	Walls	\$24,700	\$1,239	19.9	25	\$6,275	25.4%	91.0%
ESM 1-5	TOTALS	\$60,074	\$7,018	8.6	25	\$115,376	192.1%	4.4%

Investing \$60,074 into the thermal envelope or shell of the Town Hall is estimated to save \$7,018 a year heating costs based on 2019 occupancy patterns and the current price of \$3.25 per gallon of oil. At that price, a simple payback would be less than nine years and a 4.4% annual return on investment for each of the 25 years life of measure. Peak heating load reductions following the measures is described on the next page

Brief ESM Notes. Refer to images and details for each later in this report:

- 1. Add weatherstripping to all exterior doors and air seal penetrations in the floor of the attic before blowing in additional cellulose to achieve a level 18". Seal the attic hatch and rig with a pulley so that it can be easily closed.
- 2. Lay a commercial grade (>10ml) vapor barrier on the floor of the crawlspace and seal to the walls by spraying three inches closed cell foam against the foundation walls to the floor decking.
- 3. This measure is based on a proposal the Town has received to repair and restore the historic wood windows.
- 4. Restoring the windows (#3) will reduce air leakage and improve operability. Adding air tight interior glazing panels (from Innerglass.com for one example) yields additional air sealing as well as improving glazing performance.
- 5. Separated due to the relative long 'payback' by itself, insulating the exterior walls by dense packing cellulose into all cavity bays will complete an 'energy upgrade' package and improve comfort substantially.



Assumptions and Inputs

Energy savings from envelope improvements have been calculated in the energy model based on the following thermal performance values.

Envelope Component	Surface Area FT2	Existing u-Value	ESM 1 - Air Seal & Ins Attic	ESM 2 - Crawlspace/ Floor	ESM 3- Window Retrofit	ESM 4 Interior Panels	ESM 5 Insulate Walls
Walls-Frame	4940	0.19	no change	no change	no change	no change	0.048
Door	87.3	0.5	no change	no change	no change	no change	no change
Door	28.1	0.39	no change	no change	no change	no change	no change
Windows	659	0.99	no change	no change	no change	0.39	no change
Ceiling	3452	0.063	0.02	no change	no change	no change	no change
Floor over Crawl	3452	0.368	no change	0.072	no change	no change	no change
	Volume	CFM	CFM	CFM	CFM	CFM	CFM
Winter infiltration	91478	660	420	410	270	245	210
Duct Losses		36507	36507	24076	24041	23265	22585
Heating Load BTU/HR		252029	222561	192323	172326	110155	86952

In addition to saving energy and dollars annually from improving the envelope, each subsequent measure will also reduce the peak heating load. That is the amount of heat (in Btus per hour) which is lost to the outside during the near coldest hour in Deerfield, on average over the past 30 years. Also referred to as the Design Load, this informs the size of any new heating equipment installed. The capacities of the existing furnaces are not known but they likely exceed the existing peak load and will greatly exceed what is needed after implementing the ESM. However, completing all five ESM would make converting to electric heat pumps a reasonable option in the future.

Load calculation report summaries have been included at the back of this report.



Energy Audit



Conceptual Floor Plan Graphic: First Floor





Conceptual Floor Plan Graphic: Second Floor





Historic Energy Usage

Energy	Units	Site Btus	Source Btus	\$Cost
Town Hall Electric kWh	11,573	39,487,076	131,480,853	\$3,061
Pump House Electric kWh	13,341	45,519,492	151,567,101	\$2,563
Oil - gallons	3,578	326,671,400	375,672,110	\$11,629
Totals		411,677,968	658,720,064	\$17,253
EUI KBtu/FT2	6904	59.6	95.4	\$2.50

The energy analysis below is based on oil and electric consumption in 2019.

The Energy Utilization Index (EUI) offers a simple snapshot analysis of a building's energy use by looking at total amount of energy input (converted to Btu's) divided by the floor area of conditioned space. "Site Energy" refers to units of energy delivered to a site. Source energy includes transmission and total raw energy the building requires .

Based on the information provided, the Town Hall's EUI is 59.6 KBtu/ft2; Source Energy EUI is 95.4 KBtu/FT2 with energy costs at \$5.22 per sq ft in 2021 energy rates.

Read Date	Town Hall	Pump House	Total kWh	Town Hall Cost	Pump House Cost
1.16.19	2193	1659	3852	\$456.17	\$291.68
2.14.19	2068	2309	4377	\$446.10	\$374.74
3.15.19	2004	2184	4188	\$404.01	\$359.68
4.16.19	1359	1632	2991	\$342.68	\$267.33
5.16.19	448	565	1013	\$161.02	\$271.51
6.17.19	200	270	470	\$112.03	\$79.46
7.17.19	152	154	306	\$96.08	\$58.12
8.16.19	131	167	298	\$96.71	\$62.82
9.17.19	177	229	406	\$128.81	\$76.90
10.16.19	259	577	836	\$157.96	\$148.99
11.14.19	942	1485	2427	\$252.18	\$251.88
12.16.19	1640	2110	3750	\$407.13	\$319.68
	11573	13341	24914	\$3,061	\$2,563

Electric usage is lowest in the summer months and highest in the coldest months, likely due to furnace blowers and what appears to be electric resistance heating in the bathroom. Based on a base load of 200 kWh per month, heating loads potentially consume 9300 kWh. Envelope improvements will also yield electric savings, but have not been estimated for this study.

As a non-residential customer, there is also a monthly charge for KW demand, which also varies each month and may yield reductions.





Thermographic (aka Infra red or IR) images depict differences in surface temperatures. Darker colors indicate cooler surfaces, so in the winter usually mean heat loss to the outside. Streaking or 'large dark blobs' often indicate cold air infiltration, such as through the doors below. Carefully installed commercial grade weatherstripping will greatly reduce this air leakage.



At the same time, establishing a continuous air barrier at the top ceiling plane can also help reduce air leakage below by reducing the 'stack' or chimney effect as warm air rises, pulling colder outside air in at lower levels.

This first ESM is designed to reduce air infiltration and exfiltration while also improving the insulation layer above the ceiling. After air sealing targeted areas in the attic floor and insulating and weatherstripping the attic hatch, dense pack cellulose into each floor bay, then blow in additional 12" for even and level coverage.

Note: Replace lighting fixtures to Rated LED units prior to insulation. Also, rig a pulley and rope on the hatch so it will close tightly.











Installing a vapor barrier on the dirt floor and air sealing and insulating the foundation walls with closed cell foam, effectively separates soil gasses and moisture from the entire building, while reducing heat loss to the outside. It also brings the uninsulated ducts into the thermal envelope, further reducing losses.

I understand the resistance to using spray foam on historic elements, but in the case of a crawl space, there is no real or effective substitute for closed cell foam. It can adhere to uneven surfaces and does not deteriorate like fiberglass; nor house rodents, nor allow for mold growth.















The historic windows of the Town Hall, including the muntins, glazing and some sashes, are in disrepair. Restoring them is a matter of safety and preservation more than energy savings, though a proper restoration should help reduce air leakage. Ideally, rope and pulleys are replaced with quality metal tape mechanisms and the weights removed and chases filled with cellulose.

ESM 4

Installing interior, tightly sealed, but removable glazing panels is an excellent way to improve the energy performance of historic single pane windows. Many companies offer products that can be ordered on line. Custom wood units can also be made, though at a far higher cost.

The option presented here is a single, compression fitting unit from <u>Storm Windows: Commercial & Residential Interior</u> <u>Storm Window Solutions - Custom Interior Storm Windows by Innerglass, Affordable Windows, Energy Saving Windows</u>

Technically not storm windows because they are on the inside, they can—and should—be air tight to prevent air borne vapor to migrate to the now colder wood sashes where condensation will form. Exterior storms protect the window from weather and offer some reduction in heat loss but should have weep holes maintained to prevent trapping moisture inside.



Image from Innerglass website







Based on the assessment of existing conditions, the uninsulated walls of the Town Hall account for 27% of the building's heat loss. After completing ESM 4, walls would account for 32% of the building's heat loss and the next focus for improvement. The IR image below, taken from the outside when the outdoor air temperature was 30 degrees, the surface of the wall—at framing—was 47.7 degrees, and the wall cavities approximately 52 degrees. Note you can see the post and beam framing, showing as cooler since the solid wood slows the rate of heat loss more than the the rest of the assembly. The inside images also show the variations of conductive losses through the walls.



This measure calls for removing at least two clapboards (top of each floor) and drilling a two inch hole in the sheathing, then running a hose into the wall to blow in, and densely pack as much as possible without damaging the plaster, cellulose insulation. This is recommended only after completing ESM 2 which will reduce moisture loads from the basement. Humidity levels should be kept at 40% or below to eliminate the risk of excessive vapor migration into the walls. Cellulose can hold vapor without issues, then dry either to the inside or outside. With no penetrations in the wall, where air can move vapor outward in the winter, there is minimal risk of condensation on the inside of the exterior sheathing.

Deerfield Town Hall EXISTING HVAC Load Calculations

for

Town Of Deerfield 8 Raymond Road Deerfield, NH 03037





Prepared By:

Margaret Dillon S.E.E.D.S.

(603) 532-8979 Thursday, December 2, 2021

Rhvac is an ACCA approved Manual J, D and S computer program. Calculations are performed per ACCA Manual J 8th Edition, Version 2, and ACCA Manual D.

Rhvac - Residential & Light Commercial HVAC Loads							ftware Development, Inc.		
S.E.E.D.S. Jaffrey, NH 03452			1			Deer	tield Town Hall EXISTING Page 2		
Project Report									
General Project Information									
Project Title: Project Date: Client Name: Client Address: Client City: Company Name: Company Representative: Company Phone: Company E-Mail Address:	Deerfiel Wednes Town O 8 Raym Deerfiel S.E.E.D Margare (603) 53 mdillon(d Town Ha sday, Nove f Deerfield ond Road d, NH 030 0.S. et Dillon 32-8979 @myfairpo	all EXISTING ember 17, 20 37 int.net	3)21					
Design Data									
Reference City: Building Orientation: Daily Temperature Range: Latitude: Elevation: Altitude Factor:		2 34 0.98	Concord Front do High 13 Degrees 12 ft. 38	AP, New Har or faces North	mpshire 1				
Ou	tdoor C	Outdoor	Outdoor	Indoor	Indoor	Grains			
<u>Dry</u> Winter	<u>Bulb</u> <u>We</u> -2	et Bulb -2.6	<u>Rel.Hum</u> n/a	<u>Rel.Hum</u> n/a	<u>Dry Bulb</u> 70	<u>Difference</u> n/a			
Summer:	87	70	43%	50%	75	19			
Check Figures									
Total Building Supply CFM:		3	3,192	CFM Pe	er Square ft.	:	0.462 *		
Square ft. of Room Area:		6	5,904 478	Square	ft. Per Ton:		0 **		
 * Based on area of rooms l ** Based on area of rooms 	being heate	ed or coole	d (whicheve	r governs sys	tem) rather t	han entire floor	area.		
Building Loads									
Total Heating Required Incl	uding Venti	ilation Air:	252,0	29 Btuh	252.029	MBH			
Notes									
Notes Rhvac is an ACCA approved Manual J, D and S computer program. Calculations are performed per ACCA Manual J 8th Edition, Version 2, and ACCA Manual D. All computed results are estimates as building use and weather may vary. Be sure to select a unit that meets both sensible and latent loads according to the manufacturer's performance data at your design conditions.									

Rhvac - Residential & Light Commercial HVAC Loads S.E.E.D.S. Jaffrey, NH 03452



Miscel	laneous	Renort
IVIISUEI	Ianeous	ΝΕρυπ

mooonan									
System 1 Nev	ver Furnace.Main Floor		Outdoor	Outdoo	or C	Outdoor	Indoor	Indoor	Grains
Input Data			Dry Bulb	VVet Bui		el.Hum	<u>Rel.Hum</u>		Difference
Winter:			-2	-2.	6	80%	n/a	70	n/a
Summer:			87	/	0	43%	50%	75	18.65
System 2 Old	er Furnace 2nd Floor	(Outdoor	Outdoor	O	utdoor	Indoor	Indoor	Grains
Input Data			Dry Bulb	Wet Bulb	Re	I.Hum	Rel.Hum	Dry Bulb	Difference
Winter:			-2	-2.6		80%	n/a	70	n/a
Summer:			87	70		43%	50%	75	18.65
Duct Sizing In	puts								
	Main Trunk			<u>Runouts</u>					
Calculate:	Yes			Yes					
Use Schedule	e: Yes			Yes					
Roughness Fa	actor: 0.00300			0.01000					
Pressure Drop	o: 0.1000	in.wg./100 ft.		0.1000	in.wg./	/100 ft.			
Minimum Velo	ocity: 0	ft./min		0	ft./min	1			
Maximum Vel	ocity: 900	ft./min		750	ft./min	1			
Minimum Heig	ght: 6	in.		6	in.				
Maximum Hei	ght: 12	in.		10	in.				
Outside Air Da	ata								
		Winter		Sun	nmer				
Infiltration Spe	ecified:	0.433 AC/	′hr) 433	AC/hr			
	Joiniou.	660 CEN	M		660	CFM			
La Classica a Alat		0.400 0.00	vi //	~	400	A O //			
Inflitration Act	uai:	0.433 AC/	nr 4	V OI	1.433	AC/nr			
Above Grade		<u>91,478</u> Cu.	π.	<u>X 91</u>	<u>,478</u>				
		39,600 Cu.	ft./nr	35	9,600	Cu.ft./nr			
T (15 11	2			<u>X 0.</u>	0167	0514			
Total Building	Infiltration:	660 CFN	VI		660	CFM			
Total Building	Ventilation:	0 CFN	VI		0 0	CFM			
Curatara 1									
	 Iontilation Canaible Cain	Multiplier	12.04	(1 10 V	0.000	V 10 00	Summer Te	mp Difference	
	entilation Sensible Gain		13.04	= (1.10 X)	0.966	X 12.00		mp. Dinerenc	e)
Infiltration & V	entilation Latent Gain IV		70.02	= (0.68 X)	0.988	X 18.05	Grains Diffe	erence)	
Inflitration & V	entilation Sensible Loss		78.23	= (1.10 X)	0.988	X 72.00	winter i em	p. Difference)
Winter Infiltrat	ion Specified: 0.45	9 AC/nr (330 C	FM)						
Summer Infiltr	ration Specified: 0.45	9 AC/hr (330 C	FM)						
Curatara O									
System 2	 Iontilation Sanaible Cain	Multiplion	12.04	- (1 10 V	0 000	V 12 00		mp Difference))
	entilation Sensible Gain	wultiplier.	13.04	= (1.10 A)	0.966	X 12.00		mp. Dinerenc	e)
	entilation Latent Gain IV	ulupiler:	70.02	$= (0.00 \ \text{\AA})$	0.966	X 10.00		n Difference)	
Inflitration & V	ion Creation Sensible Loss		18.23	= (1.10 X)	0.988	X 72.00	winter Tem	p. Difference)
Winter Inflitrat	tion Specified: 0.41	J AC/nr (330 C							
Summer Inflitt	ration Specified: 0.41	J AC/nr (330 C	FM)						
Duct Load Fa	ctor Scenarios for Syste	m 1							
			Attic		Du	ict	Duct	Surface	From
No. Type	Description	_ocation	Ceiling		Leakag	ge Ir	sulation	Area	[T]MDD
1 Supply	(Closed Crawl E	3 -		0.	12	6	932	No
1 Return		Closed Crawl E	3 -		0.1	12	0	345	No
Duct Load Fa	ctor Scenarios for Syste	m 2							
			Attic		Du	ict	Duct	Surface	From
No. Type	Description	ocation	Ceiling		Leakad	de In	sulation	Area	
1 Supply		Closed Crawl F	3 -		0	12	6	1864	No
1 Return		Closed Crawl F			0. 0.2	12	0	690	No
i Kotuiri			-		0.		0	000	



Load Preview Report

Scope	Net Ton	ft.² /Ton	Area	Sen Gain	Lat Gain	Net Gain	Sen Loss	Sys Htg CFM	Sys Clg CFM	Sys Act CFM	Duct Size
Building	0.00	0	6,904	0	0	0	252,029	3,192	0	3,192	
System 1	0.00	0	3,452	0	0	0	127,354	1,631	0	1,631	28x12
Return Duct				0	0	0	3,296				
Zone 1			3,452	0	0	0	124,058 <mark></mark>	1,631	0	1,631	28x12
1-Main Floor			3,452	0	0	0	124,058 <mark></mark>	1,631	0	1,631	157
System 2	0.00	0	3,452	0	0	0	124,675	1,561	0	1,561	22x12
Return Duct				0	0	0	5,979				
Zone 1			3,452	0	0	0	118,696	1,561	0	1,561	22x12
2-Second Floor			3,452	0	0	0	118,696 <mark>.</mark>	1,561	0	1,561	157

Rhvac - Residential & Light Commercial HVAC Loads S.E.E.D.S. Jaffrey, NH 03452



Elite Software Development, Inc. Deerfield Town Hall EXISTING Page 5

Duct Size Preview

Cooling Flow:

0

Room or Duct Name		Source	Minimum Velocity	Maximum Velocity	Rough. Factor	Design L/100	SP Loss	Duct Velocity	Duct Length	Htg Flow	Clg Flow	Act. Flow	Duct Size
System 1													
Supply Runouts													
Zone 1													
1-Main Floor		Built-In	0	750	0.01	0.1		406.9		1,631	0	1,631	157
Other Ducts in Syst	em 1												
Supply Main Trunk	κ	Built-In	0	900	0.003	0.1		699.1		1,631	0	1,631	28x12
System 2													
Supply Runouts													
Zone 1													
2-Second Floor		Built-In	0	750	0.01	0.1		389.3		1,561	0	1,561	157
Other Ducts in Syst	em 2												
Supply Main Trunk	(Built-In	0	900	0.003	0.1		851.3		1,561	0	1,561	22x12
				Sur	nmary								
Svstem 1													
Heating Flow:	1631												
Cooling Flow:	0												
System 2													
Heating Flow:	1561												



Component	Area	Sen	Lat	Sen	Total
SPwithStorm: Glazing-Wood frame with single pape and	Quan 658 7		Gain	Gain	
alumin storm U-value 0.99 SHGC 0.64	030.7	40,947	0	0	0
11D: Door-Wood - Solid Core, U-value 0.5	87.3	3,143	0	0	0
11D: Door-Wood - Solid Core, U-value 0.39	28.1	790	0	0	0
Historic 2x4: Wall-Frame, Custom, Historic, U-value 0.19	4940.9	67,593	0	0	0
Blown in Cellulose: Roof/Ceiling-Under Attic with	3452	15,658	0	0	0
Insulation on Attic Floor (also use for Knee Walls and					
Partition Ceilings), Custom, Blown in Cellulose with					
Voids and varying depths, U-value 0.063	2452	20.761	0	0	0
on exposed walls, sealed or vented space, no insulation	3452	29,701	0	0	0
no floor insulation tile or vinyl U-value 0.368					
Subtotale for structure:		163 802	0	0	0
People:	0	105,092	0	0	0
Fauipment:	0		0	0	0
Lighting:	0		Ū.	0 0	0
Ductwork:	-	36,507	0	0	0
Infiltration: Winter CFM: 660, Summer CFM: 660		51,630	0	0	0
Ventilation: Winter CFM: 0, Summer CFM: 0		0	0	0	0
Total Building Load Totals:		252,029	0	0	0
Check Figures					
Total Building Supply CFM: 3,192	CFM P	Per Square ft.:			0.462 *
Square ft. of Room Area: 6,904	Square	e ft. Per Ton:			0 **
\/olumo (ft3): 01.479					
volume (nº). 91,478					
* Based on area of rooms being heated or cooled (whichey	ver governs sy	stem) rather th	an entire floor	area.	
* Based on area of rooms being heated or cooled (whichev ** Based on area of rooms being cooled.	ver governs sy	stem) rather th	an entire floor	area.	
* Based on area of rooms being heated or cooled (whichever * Based on area of rooms being cooled. Building Loads Tradition Description (whichever)	ver governs sys	stem) rather th	an entire floor	area.	
* Based on area of rooms being heated or cooled (whichever ** Based on area of rooms being cooled. Building Loads Total Heating Required Including Ventilation Air: 252	ver governs sys 2,029 Btuh	stem) rather th 252.029 M	an entire floor IBH	area.	
* Based on area of rooms being heated or cooled (whichever ** Based on area of rooms being cooled. Building Loads Total Heating Required Including Ventilation Air: 252 Notes	ver governs sys 2,029 Btuh	stem) rather th 252.029 N	an entire floor 1BH	area.	
* Based on area of rooms being heated or cooled (whichever ** Based on area of rooms being cooled. Building Loads Total Heating Required Including Ventilation Air: 252 Notes Rhvac is an ACCA approved Manual J, D and S computer Calculations are performed per ACCA Manual J ath Edition	ver governs sys 2,029 Btuh program.	stem) rather th 252.029 M	an entire floor IBH	area.	
* Based on area of rooms being heated or cooled (whichever ** Based on area of rooms being cooled. Building Loads Total Heating Required Including Ventilation Air: 252 Notes Rhvac is an ACCA approved Manual J, D and S computer Calculations are performed per ACCA Manual J 8th Edition All computed results are ostimates as building use and wear	2,029 Btuh program. n, Version 2, an	stem) rather th 252.029 M nd ACCA Manu	an entire floor IBH Ial D.	area.	
 * Based on area of rooms being heated or cooled (whichevertise Based on area of rooms being cooled. Building Loads Total Heating Required Including Ventilation Air: 252 Notes Rhvac is an ACCA approved Manual J, D and S computer Calculations are performed per ACCA Manual J 8th Edition All computed results are estimates as building use and weat Be sure to select a unit that meets both sensible and latent 	ver governs sys 2,029 Btuh program. n, Version 2, an ather may vary	stem) rather th 252.029 M d ACCA Manu	an entire floor IBH ial D. facturer's perf	area.	
 * Based on area of rooms being heated or cooled (whichever ** Based on area of rooms being cooled. Building Loads Total Heating Required Including Ventilation Air: 252 Notes Rhvac is an ACCA approved Manual J, D and S computer Calculations are performed per ACCA Manual J 8th Edition All computed results are estimates as building use and weat Be sure to select a unit that meets both sensible and latent your design conditions. 	ver governs sys 2,029 Btuh program. n, Version 2, an ather may vary : loads accordir	stem) rather th 252.029 M d ACCA Manu ng to the manu	an entire floor IBH Ial D. facturer's perf	area.	a at
 * Based on area of rooms being heated or cooled (whichever ** Based on area of rooms being cooled. Building Loads Total Heating Required Including Ventilation Air: 252 Notes Rhvac is an ACCA approved Manual J, D and S computer Calculations are performed per ACCA Manual J 8th Edition All computed results are estimates as building use and weat Be sure to select a unit that meets both sensible and latent your design conditions. 	ver governs sys 2,029 Btuh program. n, Version 2, an ather may vary i loads accordir	stem) rather th 252.029 M ad ACCA Manu ng to the manu	an entire floor IBH Ial D. facturer's perf	area.	a at
 * Based on area of rooms being heated or cooled (whichevertise Based on area of rooms being cooled. Building Loads Total Heating Required Including Ventilation Air: 252 Notes Rhvac is an ACCA approved Manual J, D and S computer Calculations are performed per ACCA Manual J 8th Edition All computed results are estimates as building use and weat Be sure to select a unit that meets both sensible and latent your design conditions. 	ver governs sys 2,029 Btuh program. n, Version 2, an ather may vary : loads accordir	stem) rather th 252.029 M ad ACCA Manu ng to the manu	an entire floor IBH Ial D. facturer's perf	area.	a at
 * Based on area of rooms being heated or cooled (whichevertise Based on area of rooms being cooled. Building Loads Total Heating Required Including Ventilation Air: 252 Notes Rhvac is an ACCA approved Manual J, D and S computer Calculations are performed per ACCA Manual J 8th Edition All computed results are estimates as building use and weat Be sure to select a unit that meets both sensible and latent your design conditions. 	ver governs sys 2,029 Btuh program. n, Version 2, an ather may vary c loads accordir	stem) rather th 252.029 M ad ACCA Manu ng to the manu	an entire floor IBH Ial D. facturer's perf	area.	a at
 * Based on area of rooms being heated or cooled (whichevertise Based on area of rooms being cooled. Building Loads Total Heating Required Including Ventilation Air: 252 Notes Rhvac is an ACCA approved Manual J, D and S computer Calculations are performed per ACCA Manual J 8th Edition All computed results are estimates as building use and weat Be sure to select a unit that meets both sensible and latent your design conditions.	ver governs sys 2,029 Btuh program. n, Version 2, an ather may vary : loads accordir	stem) rather th 252.029 M Ind ACCA Manu Ing to the manu	an entire floor IBH Ial D. facturer's perf	area.	a at
 * Based on area of rooms being heated or cooled (whichevertise Based on area of rooms being cooled. Building Loads Total Heating Required Including Ventilation Air: 252 Notes Rhvac is an ACCA approved Manual J, D and S computer Calculations are performed per ACCA Manual J 8th Edition All computed results are estimates as building use and weat Be sure to select a unit that meets both sensible and latent your design conditions.	ver governs sys 2,029 Btuh program. n, Version 2, an ather may vary i loads accordir	stem) rather th 252.029 M ad ACCA Manu ng to the manu	an entire floor IBH Ial D. facturer's perf	area.	a at
 * Based on area of rooms being heated or cooled (whichevertise Based on area of rooms being cooled. Building Loads Total Heating Required Including Ventilation Air: 252 Notes Rhvac is an ACCA approved Manual J, D and S computer Calculations are performed per ACCA Manual J 8th Edition All computed results are estimates as building use and weat Be sure to select a unit that meets both sensible and latent your design conditions. 	ver governs sys 2,029 Btuh program. n, Version 2, an ather may vary i loads accordir	stem) rather th 252.029 M ad ACCA Manu ng to the manu	an entire floor IBH Ial D. facturer's perf	area.	a at
 * Based on area of rooms being heated or cooled (whichever ** Based on area of rooms being cooled. Building Loads Total Heating Required Including Ventilation Air: 252 Notes Rhvac is an ACCA approved Manual J, D and S computer Calculations are performed per ACCA Manual J 8th Edition All computed results are estimates as building use and weat Be sure to select a unit that meets both sensible and latent your design conditions. 	ver governs sys 2,029 Btuh program. n, Version 2, an ather may vary i loads accordir	stem) rather th 252.029 M ad ACCA Manu ng to the manu	an entire floor IBH Ial D. facturer's perf	area.	a at
 * Based on area of rooms being heated or cooled (whicheverting Based on area of rooms being cooled. Building Loads Total Heating Required Including Ventilation Air: 252 Notes Rhvac is an ACCA approved Manual J, D and S computer Calculations are performed per ACCA Manual J 8th Edition All computed results are estimates as building use and weat Be sure to select a unit that meets both sensible and latent your design conditions.	ver governs sys 2,029 Btuh program. n, Version 2, an ather may vary : loads accordir	stem) rather th 252.029 M ad ACCA Manu ng to the manu	an entire floor IBH Ial D. facturer's perf	area.	a at
 * Based on area of rooms being heated or cooled (whicheverting Based on area of rooms being cooled. Building Loads Total Heating Required Including Ventilation Air: 252 Notes Rhvac is an ACCA approved Manual J, D and S computer Calculations are performed per ACCA Manual J 8th Edition All computed results are estimates as building use and weat Be sure to select a unit that meets both sensible and latent your design conditions. 	ver governs sys 2,029 Btuh program. n, Version 2, an ather may vary i loads accordir	stem) rather th 252.029 M ad ACCA Manu ng to the manu	an entire floor IBH Ial D. facturer's perf	area.	a at
 * Based on area of rooms being heated or cooled (whichev ** Based on area of rooms being cooled. Building Loads Total Heating Required Including Ventilation Air: 252 Notes Rhvac is an ACCA approved Manual J, D and S computer Calculations are performed per ACCA Manual J 8th Edition All computed results are estimates as building use and wea Be sure to select a unit that meets both sensible and latent your design conditions.	ver governs sys 2,029 Btuh program. n, Version 2, an ather may vary i loads accordir	stem) rather th 252.029 M ad ACCA Manu ng to the manu	an entire floor IBH Ial D. facturer's perf	area.	a at
 * Based on area of rooms being heated or cooled (whichev ** Based on area of rooms being cooled. Building Loads Total Heating Required Including Ventilation Air: 252 Notes Rhvac is an ACCA approved Manual J, D and S computer Calculations are performed per ACCA Manual J 8th Edition All computed results are estimates as building use and wea Be sure to select a unit that meets both sensible and latent your design conditions.	ver governs sys 2,029 Btuh program. n, Version 2, an ather may vary i loads accordir	stem) rather th 252.029 M ad ACCA Manu ng to the manu	an entire floor IBH Ial D. facturer's perf	area.	a at
 * Based on area of rooms being heated or cooled (whichev ** Based on area of rooms being cooled. Building Loads Total Heating Required Including Ventilation Air: 252 Notes Rhvac is an ACCA approved Manual J, D and S computer Calculations are performed per ACCA Manual J 8th Edition All computed results are estimates as building use and wea Be sure to select a unit that meets both sensible and latent your design conditions.	ver governs sys 2,029 Btuh program. n, Version 2, an ather may vary : loads accordir	stem) rather th 252.029 M ad ACCA Manu ng to the manu	an entire floor IBH Ial D. facturer's perf	area.	a at
 * Based on area of rooms being heated or cooled (whichev ** Based on area of rooms being cooled. Building Loads Total Heating Required Including Ventilation Air: 252 Notes Rhvac is an ACCA approved Manual J, D and S computer Calculations are performed per ACCA Manual J 8th Edition All computed results are estimates as building use and weat Be sure to select a unit that meets both sensible and latent your design conditions.	ver governs sys 2,029 Btuh program. n, Version 2, an ather may vary loads accordir	stem) rather th 252.029 M ad ACCA Manu ng to the manu	an entire floor IBH Ial D. facturer's perf	area.	a at
 * Based on area of rooms being heated or cooled (whichev ** Based on area of rooms being cooled. Building Loads Total Heating Required Including Ventilation Air: 252 Notes Rhvac is an ACCA approved Manual J, D and S computer Calculations are performed per ACCA Manual J 8th Edition All computed results are estimates as building use and weat Be sure to select a unit that meets both sensible and latent your design conditions.	ver governs sys 2,029 Btuh program. n, Version 2, an ather may vary i loads accordir	stem) rather th 252.029 M ad ACCA Manu ng to the manu	an entire floor IBH Ial D. facturer's perf	area.	a at
* Based on area of rooms being heated or cooled (whichev ** Based on area of rooms being cooled. Building Loads Total Heating Required Including Ventilation Air: 252 Notes Rhvac is an ACCA approved Manual J, D and S computer Calculations are performed per ACCA Manual J 8th Edition All computed results are estimates as building use and wea Be sure to select a unit that meets both sensible and latent your design conditions.	ver governs sys 2,029 Btuh program. n, Version 2, an ather may vary loads accordir	stem) rather th 252.029 M ad ACCA Manu ng to the manu	an entire floor IBH Ial D. facturer's perf	area.	a at

Rhvac - Residential & Light Commercial HVAC Loads		Elite Software Development, Inc.
S.E.E.D.S.		Deerfield Town Hall EXISTING
Jaffrey, NH 03452	••• /	Page 7
Building Pie Chart		



Glass 19%



100.0%

Conc

Detailed Room Loads - Room 1 - Main Floor

General								
Calculation Mode:	Htg. only			Occurrences	5:		1	
Room Length:	n/a			System Num	nber:		1	
Room Width:	n/a			Zone Numbe	er:		1	
Area:	3,452.0	sq.ft.		Supply Air:			1,631 CF	M
Ceiling Height:	12.5	ft.		Supply Air C	hanges:		2.3 AC	C/hr
Volume:	43,150	cu.ft.		Req. Vent. C	lg:		0 CF	M
Number of Registers:	15			Actual Winte	er Vent.:		0 CF	M
Runout Air:	109	CFM		Percent of S	upply.:		0 %	
Runout Duct Size:	7	in.		Actual Sumn	ner Vent.:		0 CF	M
Runout Air Velocity:	407	ft./min		Percent of S	upply:		0 %	
Runout Air Velocity:	407	ft./min		Actual Winte	er Infil.:		330 CF	M
Actual Loss:	0.074	in.wg./	/100 ft.	Actual Summ	ner Infil.:		0 CF	M
Item	Ar	ea	-U-	Htg	Sen	Clg	Lat	Sen
Description	Quant	ity	Value	HTM	Loss	HTM	Gain	Gain
E -Wall-Historic 2x4 74 X 12.5	744	1.5	0.190	13.7	10,185	0.0	0	0
S -Wall-Historic 2x4 27 X 10	2	70	0.190	13.7	3,694	0.0	0	0
E -Wall-Historic 2x4 10 X 10	1	00	0.190	13.7	1,368	0.0	0	0
W -Wall-Historic 2x4 10 X 10		88	0.190	13.7	1,204	0.0	0	0
W -Wall-Historic 2x4 74 X 12.5	775	5.6	0.190	13.7	10,610	0.0	0	0
N -Wall-Historic 2x4 43 X 12.5	453	3.1	0.190	13.7	6,199	0.0	0	0
N -Door-11D 3.8 X 7.4	28	3.1	0.500	36.0	1,012	0.0	0	0
N -Door-11D 3.8 X 7.4	28	3.1	0.500	36.0	1,012	0.0	0	0
N -Door-11D 3.8 X 7.4	28	3.1	0.390	28.1	790	0.0	0	0
E -Door-11D 4.2 X 7.4	31	1.1	0.500	36.0	1,119	0.0	0	0
E -Gls-SPwithStorm shgc-0.64 0%S (4)	149	9.4	0.990	71.3	10,648	0.0	0	0
W -Gls-SPwithStorm shgc-0.64 0%S		12	0.990	71.3	855	0.0	0	0
W -GIs-SPwithStorm shgc-0.64 0%S (4)	149	9.4	0.990	71.3	10,648	0.0	0	0
Floor-19A-0tp 1 X 3452	34	52	0.368	8.6	29,761	0.0	0	0
Subtotals for Structure:					89,105		0	0
Infil.: Win.: 330.0. Sum.: 0.0	2.8	58		9.034	25.815	0.000	0	0
Ductwork:	_,0			0.001	9,138	0.000	Ŭ	0
Room Totals:					124,058		0	0

Elite Software Development, Inc. Deerfield Town Hall EXISTING Page 8

General									
Calculation Mode:	Htg. only			Occurrence	S:		1		
Room Length:	n/a			System Nur	mber:		2		
Room Width:	n/a			Zone Numb	er:		1		
Area:	3,452.0 sq.ft.			Supply Air:			1,561 CFM		
Ceiling Height:	14.0	ft.		Supply Air (Changes:		1.9 AC/h	r	
Volume:	48,328	cu.ft.		Req. Vent.	Clg:		0 CFM		
Number of Registers:	15			Actual Wint	er Vent.:		0 CFM		
Runout Air:	104	CFM		Percent of S	Supply.:		0 %		
Runout Duct Size:	7	in.		Actual Sum	mer Vent.:		0 CFM		
Runout Air Velocity:	389	ft./min.		Percent of S	Supply:		0 %		
Runout Air Velocity:	389	ft./min.		Actual Wint	er Infil.:		330 CFM		
Actual Loss:	0.068	in.wg./	100 ft.	Actual Sum	mer Infil.:		0 CFM		
Item	Ar	ea	-U-	Htg	Sen	Clg	Lat	Sen	
Description	Quant	ity	Value	HTM	Loss	HTM	Gain	Gain	
E -Wall-Historic 2x4 74 X 12.5	811	.6	0.190	13.7	11,103	0.0	0	0	
S -Wall-Historic 2x4 27 X 10	2	46	0.190	13.7	3,365	0.0	0	0	
E -Wall-Historic 2x4 10 X 10		88	0.190	13.7	1,204	0.0	0	0	
W -Wall-Historic 2x4 10 X 10	1	00	0.190	13.7	1,368	0.0	0	0	
W -Wall-Historic 2x4 74 X 12.5	811	.6	0.190	13.7	11,103	0.0	0	0	
N -Wall-Historic 2x4 43 X 12.5	452	2.5	0.190	13.7	6,190	0.0	0	0	
E -Gls-SPwithStorm shgc-0.64 0%S (4)	113	3.4	0.990	71.3	8,084	0.0	0	0	
E -Gls-SPwithStorm shgc-0.64 0%S		12	0.990	71.3	855	0.0	0	0	
S -Gls-SPwithStorm shgc-0.64 0%S (2)		24	0.990	71.3	1,710	0.0	0	0	
W -GIs-SPwithStorm shgc-0.64 0%S (4)	113	8.4	0.990	71.3	8,084	0.0	0	0	
N -Gls-SPwithStorm shgc-0.64 100%S (3)	85	5.1	0.990	71.3	6,063	0.0	0	0	
UP-Ceil-Blown in Cellulose 3452 X 1	34	52	0.063	4.5	15,658	0.0	0	0	
Subtotals for Structure:					74,787		0	0	
Infil.: Win.: 330.0, Sum.: 0.0	2,8	58		9.034	25,815	0.000	0	0	
Ductwork:					18,094			0	
Room Totals:					118,696		0	0	

Detailed Room Loads - Room 2 - Second Floor

Elite Software Development, Inc. Deerfield Town Hall EXISTING Page 9



Total Dullaling Currintary Loads					
Component	Area	Sen	Lat	Sen	Total
Description	Quan	Loss	Gain	Gain	Gain
SPwithStorm: Glazing-Wood frame with single pane and alumin storm, U-value 0.99, SHGC 0.64	658.7	46,947	0	0	0
11D: Door-Wood - Solid Core, U-value 0.5	87.3	3,143	0	0	0
11D: Door-Wood - Solid Core, U-value 0.39	28.1	790	0	0	0
Historic 2x4: Wall-Frame, Custom, Historic, U-value 0.19	4940.9	67,593	0	0	0
Blown in Cellulose: Roof/Ceiling-Under Attic with Insulation on Attic Floor (also use for Knee Walls and Partition Ceilings), Custom, Blown in Cellulose with voids and varying depths, U-value 0.02	3452	4,971	0	0	0
19A-0tp: Floor-Over enclosed crawl space, No insulation on exposed walls, sealed or vented space, passive, no floor insulation, tile or vinyl, U-value 0.368	3452	29,761	0	0	0
Subtotals for structure:		153,205	0	0	0
People:	0	·	0	0	0
Equipment:			0	0	0
Lighting:	0			0	0
Ductwork:		36,502	0	0	0
Infiltration: Winter CFM: 420, Summer CFM: 420		32,854	0	0	0
Ventilation: Winter CFM: 0, Summer CFM: 0		0	0	0	0
Total Building Load Totals:		222,561	0	0	0
Check Figures					
Total Building Supply CFM: 2,807	CFM I	Per Square ft.	:		0.407 *
Square ft. of Room Area: 6,904	Squar	e ft. Per Ton:			0 **
Volume (ft ³): 91,478					
 * Based on area of rooms being heated or cooled (which ** Based on area of rooms being cooled. 	ever governs s	/stem) rather	than entire fl	oor area.	
Building Loads					
Total Heating Required Including Ventilation Air: 22	22,561 Btuh	222.561	MBH		
Notes					
Rhvac is an ACCA approved Manual J, D and S compute	r program.				

Calculations are performed per ACCA Manual J 8th Edition, Version 2, and ACCA Manual D.

All computed results are estimates as building use and weather may vary.

Be sure to select a unit that meets both sensible and latent loads according to the manufacturer's performance data at your design conditions.



Component	Area	Sen	Lat	Sen	Total
Description	Quan	Loss	Gain	Gain	Gain
SPwithStorm: Glazing-Wood frame with single pane and alumin storm. U-value 0.99. SHGC 0.64	658.7	46,947	0	0	0
11D: Door-Wood - Solid Core, U-value 0.5	87.3	3.143	0	0	0
11D: Door-Wood - Solid Core, U-value 0.39	28.1	790	0	0	0
Historic 2x4: Wall-Frame, Custom, Historic, U-value 0.19	4940.9	67,593	0	0	0
Blown in Cellulose: Roof/Ceiling-Under Attic with Insulation on Attic Floor (also use for Knee Walls and Partition Ceilings), Custom, Blown in Cellulose with voids and varying depths, U-value 0.02	3452	4,971	0	0	0
19A-0tp: Floor-Over enclosed crawl space, No insulation on exposed walls, sealed or vented space, passive, no floor insulation, tile or vinyl, U-value 0.072	3452	12,731	0	0	0
Subtotals for structure:		136,175	0	0	0
People:	0	,	0	0	0
Equipment:			0	0	0
Lighting:	0			0	0
Ductwork:		24,076	0	0	0
Infiltration: Winter CFM: 410, Summer CFM: 410		32,072	0	0	0
Ventilation: Winter CFM: 0, Summer CFM: 0		0	0	0	0
Total Building Load Totals:		192,323	0	0	0
Check Figures					
Total Building Supply CFM: 2,453	CFM P	er Square ft.	:		0.355 *
Square ft. of Room Area: 6,904	Square	ft. Per Ton:			0 **
Volume (ft ³): 91,478					
 * Based on area of rooms being heated or cooled (whicher ** Based on area of rooms being cooled. 	ver governs sys	stem) rather	than entire fl	oor area.	
Building Loads					
Total Heating Required Including Ventilation Air: 192	2,323 Btuh	192.323	MBH		
Notes					
Rhvac is an ACCA approved Manual J, D and S computer Calculations are performed per ACCA Manual J 8th Edition All computed results are estimates as building use and we Be sure to select a unit that meets both sensible and latent	program. n, Version 2, an ather may vary. t loads accordir	d ACCA Ma	nual D. nufacturer's c	performance	data at

your design conditions.



rotar Bunanig Currintary Loudo					
Component	Area	Sen	Lat	Sen	Total
Description	Quan	Loss	Gain	Gain	Gain
SPwithStorm: Glazing-Wood frame with single pane and alumin storm. U-value 0.8. SHGC 0.64	658.7	37,935	0	0	0
11D: Door-Wood - Solid Core, U-value 0.5	87.3	3.143	0	0	0
11D: Door-Wood - Solid Core, U-value 0.39	28.1	790	0	0	0
Historic 2x4: Wall-Frame, Custom, Historic, U-value 0.19	4940.9	67.593	0	0	0
Blown in Cellulose: Roof/Ceiling-Under Attic with Insulation on Attic Floor (also use for Knee Walls and Partition Ceilings), Custom, Blown in Cellulose with voids and varying depths, U-value 0.02	3452	4,971	0	0	0
19A-0tp: Floor-Over enclosed crawl space, No insulation on exposed walls, sealed or vented space, passive, no floor insulation, tile or vinyl, U-value 0.072	3452	12,731	0	0	0
Subtotals for structure:		127,163	0	0	0
People:	0	,	0	0	0
Equipment:			0	0	0
Lighting:	0			0	0
Ductwork:		24,041	0	0	0
Infiltration: Winter CFM: 270, Summer CFM: 270		21,122	0	0	0
Ventilation: Winter CFM: 0, Summer CFM: 0		0	0	0	0
Total Building Load Totals:		172,326	0	0	0
Check Figures					
Total Building Supply CFM: 2,192	CFM P	er Square ft.	:		0.317 *
Square ft. of Room Area:6,904Volume (ft³):91,478	Square	e ft. Per Ton:			0 **
 * Based on area of rooms being heated or cooled (whiche ** Based on area of rooms being cooled. 	ever governs sy	stem) rather	than entire flo	oor area.	
Building Loads					
Total Heating Required Including Ventilation Air: 17	2,326 Btuh	172.326	MBH		
Notes					
Rhvac is an ACCA approved Manual J, D and S computer Calculations are performed per ACCA Manual J 8th Editio All computed results are estimates as building use and we Be sure to select a unit that meets both sensible and later your design conditions.	⁻ program. n, Version 2, ar eather may vary it loads accordii	nd ACCA Ma ng to the ma	nual D. nufacturer's p	erformance o	lata at



Component	Area	Sen	Lat	Sen	Total
SD with Int Depole: Clearing Historia single none with	Quali 659.7	19,406	Gaili	Gain	Gaill
interior panels, U-value 0.39, SHGC 0.6	000.7	10,490	0	0	0
11D: Door-Wood - Solid Core, U-value 0.5	87.3	3,143	0	0	0
11D: Door-Wood - Solid Core, U-value 0.39	28.1	790	0	0	0
Historic 2x4: Wall-Frame, Custom, Historic, U-value 0.1	4940.9	35,577	0	0	0
R50 Roxul: Roof/Ceiling-Under Attic with Insulation on Attic Floor (also use for Knee Walls and Partition Ceilings), Custom, R50 Blown in Roxul (or cellulose), U-value 0.02	3452	4,971	0	0	0
19C1-11osp: Floor-Over enclosed crawl space, R-11 insulation on exposed walls, spray foam insulation, sealed crawl space, passive, R-11 open cell 1/2 lb. spray foam, 3 inches in 2 x 10 joist cavity, U-value 0.072	3452	4,748	0	0	0
Subtotals for structure:		67,725	0	0	0
People:	0		0	0	0
Equipment:			0	0	0
Lighting:	0			0	0
Ductwork:		23,265	0	0	0
Infiltration: Winter CFM: 245, Summer CFM: 245		19,165	0	0	0
Ventilation: Winter CFM: 0, Summer CFM: 0		0	0	0	0
Total Building Load Totals:		110,155	0	0	0
Check Figures					
Total Building Supply CEM ⁻ 1 381	CEM	Per Square ft	•		0 200 *
Square ft. of Room Area: 6,904 Volume (ft ³): 91,478	Squar	e ft. Per Ton:			0 **
 * Based on area of rooms being heated or cooled (whiche ** Based on area of rooms being cooled. 	ever governs s	ystem) rather	than entire fl	oor area.	
Building Loads					
Total Heating Required Including Ventilation Air: 11	0,155 Btuh	110.155	MBH		
Notes					
Rhvac is an ACCA approved Manual J, D and S computer Calculations are performed per ACCA Manual J 8th Editio All computed results are estimates as building use and we Be sure to select a unit that meets both sensible and later your design conditions.	r program. n, Version 2, a eather may var nt loads accord	nd ACCA Mar y. ling to the mar	nual D. nufacturer's p	performance	data at

Component	Area	Sen	Lat	Sen	Total
Description	Quan	Loss	Gain	Gain	Gain
SP with Int Panels: Glazing-Historic single pane with interior panels. U-value 0.39. SHGC 0.6	658.7	18,496	0	0	0
11D: Door-Wood - Solid Core, U-value 0.5	87.3	3.143	0	0	0
11D: Door-Wood - Solid Core, U-value 0.39	28.1	790	0	0	0
Rock Wool 4": Wall-Frame, Custom, Dense packed	4048.9	13,993	0	0	0
Rock Wool 4": Wall-Frame, Custom, Dense packed cavities with 4" Rock Wool, U-value 0.028	892	1,798	0	0	0
R50 Roxul: Roof/Ceiling-Under Attic with Insulation on Attic Floor (also use for Knee Walls and Partition Ceilings), Custom, R50 Blown in Roxul (or cellulose), U-value 0.02	3452	4,971	0	0	0
19C1-11osp: Floor-Over enclosed crawl space, R-11 insulation on exposed walls, spray foam insulation, sealed crawl space, passive, R-11 open cell 1/2 lb. spray foam, 3 inches in 2 x 10 joist cavity, U-value 0.072	3452	4,748	0	0	0
Subtotals for structure:		47,939	0	0	0
People:	0	,	0	0	0
Equipment:			0	0	0
Lighting:	0			0	0
Ductwork:		22,585	0	0	0
Infiltration: Winter CFM: 210, Summer CFM: 210		16,428	0	0	0
Ventilation: Winter CFM: 0, Summer CFM: 0		0	0	0	0
Total Building Load Totals:		86,952	0	0	0
Check Figures					
Total Building Supply CFM:1,081Square ft. of Room Area:6,904Volume (#3):01.478	CFM F Squar	Per Square ft. e ft. Per Ton:	.:		0.157 * 0 **
 * Based on area of rooms being heated or cooled (whiche ** Based on area of rooms being cooled. 	ever governs sy	/stem) rather	than entire fl	oor area.	
Building Loads					
Total Heating Required Including Ventilation Air: 8	86,952 Btuh	86.952	MBH		
Notes					

Rhvac is an ACCA approved Manual J, D and S computer program.

Calculations are performed per ACCA Manual J 8th Edition, Version 2, and ACCA Manual D.

All computed results are estimates as building use and weather may vary.

Be sure to select a unit that meets both sensible and latent loads according to the manufacturer's performance data at your design conditions.